

TENT REQUIREMENTS

- A. Site Plan
- B. Tent(s) size
- C. Number of stakes (anchors) and uplift rating for each stake
- D. Certificate of Flame Resistance for tent material
- E. The following items shall be required during inspection;
 - 1. Tent shall not be located within 20 feet of lot lines, buildings and parked vehicles or internal combustion engines (Section 2403) Ohio Fire Code.
 - 2. An unobstructed fire break passageway or fire road not less than 12 feet wide and free from guy ropes or other obstructions shall be maintained on all side of tent (Section 2403.8.5) Ohio Fire Code.
 - 3. "No smoking" signs shall be conspicuously posted in structure (Section 2404.6) Ohio Fire Code.
 - 4. Cooking shall not be permitted inside or located within 20 feet of the tent (Section 2404.7) Ohio Fire Code.
 - 5. Fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use (Section 906) Ohio Fire Code.
 - 6. Fire extinguishers shall not be obstructed or obscured from view (Section 906) Ohio Fire Code.
 - 7. Hand held portable fire extinguishers, not housed in cabinets, shall be installed on the hangars or brackets supplied (Section 906) Ohio Fire Code.
 - 8. Provide a minimum of two (2) exits (Table 2403.12.2) Ohio Fire Code.
 - 9. Exits shall be clearly marked. Exit signs shall be installed at required exit doorways and wherever necessary to indicate clearly the direction of egress (Section 2403.12.6) Ohio Fire Code. Exit signs not required on open sided tents unless a corridor is established by booths, etc.
 - 10. Occupants to evacuate the tent(s), if necessary. When wind speed meets or exceeds 40 MPH.